Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements



PennState Lehigh Valley Campus Center Valley, PA

Michael Joaquino | Mechanical Option B.A.E. Program

AE Senior Thesis Presentation Advisor: Dr. Donghyun Rim April 11th, 2017



Penn State Lehigh Valley – University Education Use Building

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

General Information


Gross Building: 96,274 SF

Construction: Spring 2002 – Fall 2003

Purchased by Penn State: 2009 - \$12 Million USD

Occupancy: 2000 Students

Building Features: Classrooms, Offices, Open Lounges, Computer Labs, Gym, Music Room, library, etc.



Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements


Existing Mechanical System

- (3) Packaged Roof-top Units with VAV Electric Reheat
 - Cooling Internal DX-Cooling Cycle
 - Heating Gas Fired Furnace

(77) VAV with Electric Reheat

Serves individual zones with modulating air dampers to accommodate the room loads.

| Existing Mechanical Specification | Cooling (kBtu-h) | Heating (kBtu-h) | CFM | O/A Min. |
|-----------------------------------|------------------|------------------|-------|-------------|
| RTU-1 | 1492 | 2350.8 | 40740 | 10725 |
| RTU-2 | 751.6 | 1059.2 | 19770 | 4125 |
| RTU-3 | 1512 | 2365.4 | 33748 | 14415 |



Building Overview – RTU placement

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth


Geothermal Design


Conclusion

Summary & Acknowledgements

Existing Mechanical System

- (3) Packaged Roof-top Units with VAV Electric Reheat
 - Cooling Internal DX-Cooling Cycle
 - Heating Gas Fired Furnace





Building Overview – RTU placement

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth


Geothermal Design

Conclusion

Summary & Acknowledgements

Design Motivation


- **Energy Efficient**
- **Economic Feasibility**
- **Functionality**



~620 SF

Design Constraints

- Limited MER Space
- No existing CHW/HHW Plumbing



Building Overview – RTU placement

Design Motivation

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth


Geothermal Design

Conclusion

Summary & Acknowledgements

Energy Efficient

- **Economic Feasibility**
- **Functionality**



~620 SF

Design Constraints

- Limited MER Space
- No existing CHW/HHW Plumbing



Michael Joaquino

Penn State Lehigh Valley Building

Penn State University – Architecture Engineering

Design Motivation

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth


Geothermal Design

Conclusion

Summary & Acknowledgements

Energy Efficient

- **Economic Feasibility**
- **Functionality**



~620 SF

Design Constraints

- Limited MER Space
- No existing CHW/HHW Plumbing



Imagery ©2017 Google, Map data ©2017 Google 100 ft

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Design Motivation

Centralized Geothermal System Geothermal GSHP + (Distributed System)

- Utilizing the ground as a heat sink & source
- Potential for large energy savings
- Minimal disruption to academic schedule

Ground Loop Incentives

- Lower Operating Costs
- Lower Carbon Emissions
- Long Life Expectancy
- Efficiency
- Heat-recovery system
- High-efficiency heat pumps
- Utilization of earth temperature

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion


Summary & Acknowledgements

Design Motivation

Centralized Geothermal System Geothermal GSHP + (Distributed System)

- Utilizing the ground as a heat sink & source
- Potential for large energy savings
- Minimal disruption to academic schedule

IES Virtual Environment



Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design **Technical Analysis** Cost

Construction Breadth

Geothermal Design

Conclusion


Summary & Acknowledgements

Design Motivation

Centralized Geothermal System Geothermal GSHP + (Distributed System)

- Utilizing the ground as a heat sink & source
- Potential for large energy savings
- Minimal disruption to academic schedule

IES Virtual Environment – DOAS with Geothermal Ground Loop



| Proposed System | Unit |
|-----------------|-------------------------|
| Central Plant | GSHP |
| Zone | Split System Heat Pumps |

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design **Technical Analysis** Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements


Design Motivation

Centralized Geothermal System Geothermal GSHP + (Distributed System)

- Utilizing the ground as a heat sink & source
- Potential for large energy savings
- Minimal disruption to academic schedule

| | DOA | \S 1 | DOA | AS 2 | DOA | 4S 3 |
|--------------------|-------|-------|-------|-------|-------|-------|
| Proposed System | CFM | 10725 | CFM | 4125 | CFM | 14415 |
| Coil-Sizes | CC | HC | CC | HC | CC | HC |
| kBTU/Hr | 676.1 | 591.5 | 246.8 | 243.9 | 913.3 | 826.1 |
| Tons | 56.3 | 49.3 | 20.6 | 20.3 | 76.1 | 68.8 |

IES Virtual Environment – DOAS with Geothermal Ground Loop



| Proposed System | Unit |
|-----------------|-------------------------|
| Central Plant | GSHP |
| Zone | Split System Heat Pumps |

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements


Geothermal System – Distributed System

Winter – Heating (Heat Source)



Summer – Cooling (Heat Sink)

Cooling Only



Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost


Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements


Geothermal System – Distributed System





Summer – Cooling (Heat Sink)

Heating Only



Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design


Conclusion

Summary & Acknowledgements

Centralized Geothermal System – Bidirectional Cascade System

- Winter Heating (Heat Source)
- Spring/Fall Capable of cooling & heating
 - Summer Cooling (Heat Sink)
 - Heat Recovery Chiller

Bidirectional Cascade System



("Central Geothermal System Design and Control" – Trane Commercial.)

Centralized Geothermal System – Bidirectional Cascade System

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost


Construction Breadth

Geothermal Design

Conclusion


Summary & Acknowledgements

Centralized Geothermal System **Building Cooling & Heating Demand**



Bidirectional Cascade System

Heating Dominate



("Central Geothermal System Design and Control" – Trane Commercial.)

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis

Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Comparing Heating & Cooling Performance

- Geothermal with Split System
- Geothermal with Chiller/Boiler
- Existing Mechanical

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion


Summary & Acknowledgements


Comparing Heating & Cooling Performance

Geothermal with Split System


- Geothermal with Chiller/Boiler
- Existing Mechanical

| Annual Electric Heating | GSHP+CHW/HHW | GSHP+HP | Baseline |
|-------------------------|--------------|-----------|-----------|
| Summed total (kWh) | 89,554.2 | 269,383.2 | 814,526.9 |
| Difference % | 0.89 | 0.76 | - |









Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design **Technical Analysis** Cost

Construction Breadth

Geothermal Design


Conclusion

Summary & Acknowledgements

Comparing Heating & Cooling Performance


...Fossil Fuel Consumption

- Geothermal with Split System
- Geothermal with Chiller/Boiler
- Existing Mechanical



Annual Electricity Distribution – Proposed System





Comparing Heating & Cooling Performance

Geothermal with Split System

...In Summary

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design **Technical Analysis** Cost

Construction Breadth

Geothermal Design


Conclusion

Summary & Acknowledgements

Geothermal with Chiller/Boiler

Existing Mechanical

| Annual Total | boilers energy (MBtu) | chillers energy (MBtu) | DX cooling systems energy (MBtu) | EHC heating energy (MBtu) |
|------------------------|-----------------------------|------------------------------|---|---------------------------------|
| Geothermal+ CHW/HHW | 9,561.95 | 480.867 | 0.00 | 0 |
| Geothermal+ HP | 8,388.67 | 310.931 | 247.92 | 0 |
| Baseline | 8,388.67 | 0 | 967.48 | 2,777.137 |



Annual Electricity Distribution – Proposed System



Michael Joaquino

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Cost Analysis

| Annual Heating/Cooling | Fossil Fue | el (Mbtu) | Electric (Mbtu) | | | Total | |
|--------------------------|------------|-----------|-----------------|---------|-------------|-------------|---------------|
| | Heating | Cooling | Heating | Cooling | Heating | Cooling | |
| seline | - | - | 3411.93 | 967.48 | \$ 90,994.2 | \$ 25,802.1 | \$ 107,761.22 |
| ech. Proposed Geothermal | - | - | 657.49 | 558.86 | \$ 17,534.9 | \$ 14,904.4 | \$ 32,439.27 |
| nditional Chiller-Boiler | 1568.54 | - | 918.47 | 462.17 | \$ 41,198.7 | \$ 12,325.9 | \$ 53,524.56 |
| . Geothermal+EWC/Boiler | 1173.29 | - | 305.34 | 480.87 | \$ 20,637.7 | \$ 12,824.5 | \$ 33,462.21 |

Cost Analysis

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

| Annual Heating/Cooling | Fossil Fuel (Mbtu) Electric (Mbtu) | | | Total | | | |
|----------------------------|------------------------------------|---------|---------|---------|-------------|-------------|---------------|
| | Heating | Cooling | Heating | Cooling | Heating | Cooling | |
| Baseline | - | - | 3411.93 | 967.48 | \$ 90,994.2 | \$ 25,802.1 | \$ 107,761.22 |
| Mech. Proposed Geothermal | - | - | 657.49 | 558.86 | \$ 17,534.9 | \$ 14,904.4 | \$ 32,439.27 |
| raditional Chiller-Boiler | 1568.54 | - | 918.47 | 462.17 | \$ 41,198.7 | \$ 12,325.9 | \$ 53,524.56 |
| Alt. Geothermal+EWC/Boiler | 1173.29 | - | 305.34 | 480.87 | \$ 20,637.7 | \$ 12,824.5 | \$ 33,462.21 |

| Vertical Well – | Proposed System | | | Original | | |
|--------------------------|-----------------|--------------|--|----------|--------------|--|
| Payback Calc | | | | | | |
| Operating Cost | \$ | 32,439.27 | | \$ | 107,761.22 | |
| Yearly Savings | \$ | 75,321.95 | | | - | |
| Equipment & Installation | \$ 3 | 3,353,074.40 | | \$ 2 | 2,642,025.00 | |
| Total (Years) | 9.4 | | | | | |

| rizontal Well ayback Calc | Proposed System | | | Original | | |
|---|-----------------|--------------|------|----------|-------------------|--|
| erating Cost | \$ | 32,439.27 | | \$ | 107,761.22 | |
| arly Savings | \$ | 75,321.95 | | | - | |
| uipment & Installation | \$ | 2,277,274.40 | | \$ | 2,642,025.00 | |
| tal (Years) | | | -4.8 | | | |
| arly Savings uipment & Installation tal (Years) | \$ \$ | • | -4.8 | \$ | - 2,642,025.00 | |

Construction Layout – Geothermal System

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design


Conclusion

Summary & Acknowledgements


Silt Loam vs. Limestone

Geothermal Well types Horizontal vs Vertical

| Geothermal Cost | Vertical | Horizontal |
|--------------------|-------------|------------|
| \$/Ft. | \$16 | \$4 |
| Ft. Req. | 47,211.3 | 54,370.2 |
| Cost | \$755,380.8 | 217.480.8 |



Proposed Geothermal Location



| Heating | Limestone | Silt Loam |
|------------|-----------|-----------|
| Lh [ft] | 41,053.3 | 47,278.43 |
| safety 15% | 47,211.29 | 54,370.19 |

Construction Layout – Geothermal System

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Silt Loam vs. Limestone

Geothermal Well types Horizontal vs Vertical

| eothermal ost | Vertical | Horizontal |
|------------------|-------------|------------|
| /Ft. | \$16 | \$4 |
| t. Req. | 47,211.3 | 54,370.2 |
| | | |
| ost | \$755,380.8 | 217,480.8 |


Table 5 Thermal Properties of Selected Soils, Rocks, and Bore Grouts/Fills

| | Dry Density, lb/ft ³ | Conductivity, Btu/h·ft·°F | Diffusivity, ft²/day |
|------------------------------------|------------------------------------|------------------------------|-------------------------|
| ils | | | |
| avy clay, 15% water | 120 | 0.8 to 1.1 | 0.45 to 0.65 |
| % water | 120 | 0.6 to 0.8 | 0.5 to 0.65 |
| ght clay, 15% water | 80 | 0.4 to 0.6 | 0.35 to 0.5 |
| % water | 80 | 0.3 to 0.5 | 0.35 to 0.6 |
| avy sand, 15% water | 120 | 1.6 to 2.2 | 0.9 to 1.2 |
| % water | 120 | 1.2 to 1.9 | 1.0 to 1.5 |
| ght sand, 15% water | 80 | 0.6 to 1.2 | 0.5 to 1.0 |
| % water | 80 | 0.5 to 1.1 | 0.6 to 1.3 |
| cks | | | |
| anite | 165 | 1.3 to 2.1 | 0.9 to 1.4 |
| nestone | 150 to 175 | 1.4 to 2.2 | 0.9 to 1.4 |
| ndstone | | 1.2 to 2.0 | 0.7 to 1.2 |
| ale, wet | 160 to 170 | 0.8 to 1.4 | 0.7 to 0.9 |
| lry | | 0.6 to 1.2 | 0.6 to 0.8 |
| outs/Backfills | | | |
| ntonite (20 to 30% solie | ds) | 0.42 to 0.43 | |
| at cement (not recomm | ended) | 0.40 to 0.45 | |
| % bentonite/80% SiO ₂ | sand | 0.85 to 0.95 | |
| % bentonite/85% SiO ₂ : | sand | 1.00 to 1.10 | |
| % bentonite/90% SiO ₂ : | sand | 1.20 to 1.40 | |
| % concrete/70% SiO ₂ s | and, | 1.20 to 1.40 | |
| . plasticizer | | | |
| was Kayanaugh and Paffa | eto (1007) | | |

Source: Kavanaugh and Rafferty (1997).

ASHRAE 2007 Fundamentals: HVAC Applications

Proposed Geothermal Location



| Heating | Limestone | Silt Loam |
|------------|-----------|-----------|
| Lh [ft] | 41,053.3 | 47,278.43 |
| safety 15% | 47,211.29 | 54,370.19 |

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design **Technical Analysis** Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Construction Layout – Geothermal System


Silt Loam vs. Limestone

Geothermal Well types Horizontal vs Vertical

Approximately 47,000 Ft. of Bore

- 11x11 Grid
- 400' Bore Depth


| Vall Depth ft) | • | Number of Wells |
|-------------------|----------|--------------------|
| 100 | 47,211.3 | 472 |
| 200 | 47,211.3 | 236 |
| 300 | 47,211.3 | 158 |
| 400 | 47,211.3 | 118 |




Proposed Geothermal Location

Summary & Conclusion

Introduction **Building Introduction Existing Mechanical** Mechanical Depth Proposed Design Technical Analysis Cost Construction Breadth Geothermal Design Conclusion Summary & Acknowledgements



Annual System Energy



■ Geothermal+HP ■ Baseline

Summary & Conclusion

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost


Construction Breadth


Geothermal Design

Conclusion

Summary & Acknowledgements

Recommendation





Summary & Conclusion

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Acknowledgements

- Dr. Donghuyn Rim Thesis Advisor
- Penn State & the Office of Physical Plant
 - Friends and Family
- **PSU AE Department & Class of 2017**





Questions

Introduction

Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost


Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

| | DOA | DOAS 1 | | DOAS 2 | | DOAS 3 | |
|--------------------|-------|--------|-------|--------|-------|--------|--|
| Proposed System | CFM | 10725 | CFM | 4125 | CFM | 14415 | |
| Coil-Sizes | CC | HC | CC | HC | CC | НС | |
| kBTU/Hr | 676.1 | 591.5 | 246.8 | 243.9 | 913.3 | 826.1 | |
| Tons | 56.3 | 49.3 | 20.6 | 20.3 | 76.1 | 68.8 | |



Building Introduction

Existing Mechanical

Mechanical Depth

Proposed Design

Technical Analysis

Cost

Construction Breadth

Geothermal Design

Conclusion


Summary & Acknowledgements

Appendix

Appendix

| Annual Heating/Cooling | Fossil Fue | el (Mbtu) | Electri | c (Mbtu) | | Cost | Total |
|----------------------------|------------|-----------|---------|----------|-------------|-------------|---------------------|
| | Heating | Cooling | Heating | Cooling | Heating | Cooling | |
| Baseline | - | - | 3411.93 | 967.48 | \$ 90,994.2 | \$ 25,802.1 | \$ 107,761.22 |
| Mech. Proposed Geothermal | - | - | 657.49 | 558.86 | \$ 17,534.9 | \$ 14,904.4 | \$ 32,439.27 |
| Traditional Chiller-Boiler | 1568.54 | - | 918.47 | 462.17 | \$ 41,198.7 | \$ 12,325.9 | \$ 53,524.56 |
| Alt. Geothermal+EWC/Boiler | 1173.29 | - | 305.34 | 480.87 | \$ 20,637.7 | \$ 12,824.5 | \$ 33,462.21 |

| Vertical Well – | Proposed System | | Original | |
|--------------------------|-----------------|--------------|----------|-----------------|
| Payback Calc | | | | |
| Operating Cost | \$ | 32,439.27 | | \$ 107,761.22 |
| Yearly Savings | \$ | 75,321.95 | | - |
| Equipment & Installation | \$ 3 | 3,353,074.40 | | \$ 2,642,025.00 |
| Total (Years) | | | 9.4 | |



Appendix – Heat and Cooling Load



Building Introduction Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis Cost


Construction Breadth


Geothermal Design

Conclusion


Summary & Acknowledgements


Appendix





System Electricity - Cooling





Appendix - Annual Loads

Introduction

Building Introduction

Existing Mechanical

Mechanical Depth

Proposed Design

Technical Analysis

Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Appendix

| rstem Cooling Coil - eothermal Supplied | Total load (MBtu) | | |
|--|-----------------------|------------|----------|
| ooling Coil | CC000777 | CC000779 | CC000781 |
| ate | [Proposed- DOASx3- | [Proposed- | DOASx3- |
| n | 0 | 0 | 0 |
| eb | 0 | 0 | 0 |
| ar | 0.091 | 0.07 | 0.046 |
| or | 5.325 | 2.093 | 7.22 |
| ay | 31.03 | 12.269 | 43.36 |
| n | 78.853 | 30.122 | 110.808 |
| l | 123.913 | 48.856 | 172.944 |
| ıg | 107.06 | 40.731 | 149.675 |
| ep | 70.99 | 27.024 | 98.829 |
| ct | 15.893 | 6.244 | 22.01 |
| ov | 6.27 | 2.373 | 8.782 |
| ec | 0 | 0 | 0 |
| ımmed total | 439.425 | 169.782 | 613.673 |
| | | | |
| otal Annual MBtu | 1222.88 | | |
| otal Annual Tons | 101906.67 | | |
| otal Annual kBTU/Hr | 139.60 | | |

| System Heating Coil - Geothermal Supplied | Sonsible load | Sensible load | Sonsible load |
|--|-----------------------|-----------------------|-----------------------|
| ocomerma supplied | (MBtu) | (MBtu) | (MBtu) |
| Heating Coil | HC002820 | HC002822 | HC002824 |
| | p_3.18.17 | p_3.18.17 | p_3.18.17 |
| | [Proposed- DOASx3- | [Proposed- DOASx3- | [Proposed- DOASx3- |
| | | | |
| Date | GSHP1.UJ.aps | GSHP1.0].aps | GSHP1.UJ.aps |
| Jan | 109.231 | 45.041 | 152.924 |
| Feb | 92.52 | 38.15 | 129.528 |
| Mar | 60.249 | 24.843 | 84.349 |
| Apr | 27.274 | 11.246 | 38.183 |
| May | 4.479 | 1.847 | 6.271 |
| Jun | 0.098 | 0.04 | 0.137 |
| Jul | 0 | 0 | 0 |
| Aug | 0.006 | 0.003 | 0.009 |
| Sep | 0.318 | 0.131 | 0.445 |
| Oct | 15.453 | 6.372 | 21.634 |
| Nov | 45.109 | 18.6 | 63.152 |
| Dec | 90.328 | 37.246 | 126.46 |
| Summed total | 445.066 | 183.519 | 623.093 |
| | | | |
| Total Annual MBtu | 1251.678 | | |
| Total Annual Tons | 104306.50 | | |
| Total Annual kBTU/Hr | 142.89 | | |

| Total System | | | | |
|--------------|---------------|---------------|--------------|--------------|
| Energy | Total system | Total system | Total system | Total system |
| | energy | energy | energy | energy |
| | (MBtu) | (MBtu) | (MBtu) | (MBtu) |
| | - — | p_3.19.17 | · — | p_3.16.17 |
| | Proposed2.0. | Alternative | - • | Baseline.aps |
| | aps | Proposed.ap | | |
| | | S | GSHP1.0].aps | |
| | Geothermal+ | | Geothermal+ | |
| ite | ChillerBoiler | ChillerBoiler | HP | Baseline |
| n | 1030.38 | 1280.64 | 863.841 | 1339.67 |
| b | 932.74 | 1147.46 | 797.172 | 1199.06 |
| ar | 955.56 | 1095.86 | 848.004 | 1157.32 |
| or | 846.48 | 909.42 | 782.836 | 1004.22 |
| ay | 776.46 | 783.46 | 755.547 | 942.43 |
| n | 833.61 | 824.98 | 828.633 | 1019.70 |
| | 883.43 | 865.75 | 881.603 | 1059.81 |
| ıg | 861.46 | 845.86 | 856.314 | 1052.59 |
| р | 827.67 | 818.72 | 817.083 | 1029.44 |
| ct | 810.15 | 840.29 | 755.801 | 986.09 |
| ΟV | 906.42 | 1006.67 | 806.934 | 1102.37 |
| ec | 1045.53 | 1251.64 | 890.097 | 1310.17 |
| mmed total | 10709.88 | 11670.73 | 9883.867 | 13202.87 |
| vs Baseline | 0.19 | | | |

Appendix – Geothermal Calcs

Introduction

Building Introduction

Existing Mechanical

Mechanical Depth

Proposed Design

Technical Analysis

Cost

Construction Breadth

Geothermal Design

Conclusion

Summary & Acknowledgements

Appendix

| ooling | Limestone | Silt Loam | Difference |
|-------------|-----------|-----------|------------|
| sc | 1.04 | 1.04 | |
| LFm | 1 | 1 | |
| a [Btu/Hr] | -133713.1 | -133713.1 | |
| ga | 0.201 | 0.225 | |
| gd | 0.120 | 0.108 | |
| gm | 0.225 | 0.201 | |
| b | 0.09 | 0.09 | |
| 3 | 52 | 52 | |
| 0 | -1.8 | -1.8 | |
| LT | 78 | 78 | |
| LT | 85 | 85 | |
| lc [Btu/Hr] | -1532563 | -1532563 | |
| Vc [W] | 4340 | 4340 | |
| c [ft^2] | 25478.62 | 23562.02 | -1916.60 |
| afety 15% | 29300.41 | 27096.33 | |

| Heating | Limestone | Silt Loam | Difference |
|--------------|------------|-----------|------------|
| Fsc | 1.04 | 1.04 | |
| PLFm | 1 | 1 | |
| Qa [Btu/Hr] | 136409 | 136409.1 | |
| Rga | 0.201 | 0.225 | |
| Rgd | 0.120 | 0.108 | |
| Rgm | 0.225 | 0.201 | |
| Rb | 0.09 | 0.09 | |
| tg | 52 | 52 | |
| tp | 1.8 | 1.8 | |
| ELT | 38 | 38 | |
| LLT | 33 | 33 | |
| qlc [Btu/Hr] | 1663419 | 1663419 | |
| Wc [W] | 4340 | 4340 | |
| Lh [ft^2] | 41053.2971 | 47278.43 | 6225.13 |
| | 47211.29 | 54370.19 | |

 \mathbf{F}_{sc} = short-circuit heat loss factor

L_c = required bore length for cooling, ft.

 L_h = required bore length for heating, ft.

PLF_m=part-load factor during design month

 \mathbf{q}_{a} = net annual average heat transfer to ground, Btu/h.

 q_{lc} = building design cooling block load, Btu/h.

q_{lh} =building design heating block load, Btu/h.

 \mathbf{R}_{ga} = effective thermal resistance of ground (annual pulse), ft-h-°F /Btu.

 \mathbf{R}_{gd} = effective thermal resistance of ground (peak daily pulse: 1 hr min, 4 – 6 hr recommended), ft-h-°F/Btu.

 \mathbf{R}_{gm} = effect thermal resistance of ground (monthly pulse), ft-h-°F /Btu.

 $\mathbf{R_h}$ = thermal resistance of bore, ft-h-°*F*/Btu.

 $\mathbf{t_g}$ = undisturbed ground temperature, °F

 $\mathbf{t_n}$ = temperature penalty for interference of adjacent bores, °F

t_{wi} = liquid temperature at heat pump inlet, °F

 \mathbf{t}_{wo} = liquid temperature at heat pump outlet, °F

W_c = system power input at design cooling load, W

W_h = system power input at design heating load, W

Building Introduction

Existing Mechanical

Mechanical Depth

Proposed Design Technical Analysis

Cost

Construction Breadth

Geothermal Design

Conclusion

Penn State Lehigh Valley Building


Summary & Acknowledgements

Appendix

Michael Joaquino

Appendix – Z_Proposal

| Annual Heating/Cooling | Fossil Fuel (Mbtu) | | Electric (Mbtu) | | Cost | | Total |
|---------------------------|--------------------|---------|-----------------|---------|-------------|-------------|---------------|
| | Heating | Cooling | Heating | Cooling | Heating | Cooling | |
| Baseline | 741.313 | - | 2777.14 | 967.48 | | | |
| | | | | | \$ 81,959.2 | \$ 25,802.1 | \$ 107,761.22 |
| Mech. Proposed | - | - | 657.49 | 558.86 | | | |
| | | | | | \$ 17,534.9 | \$ 14,904.4 | \$ 32,439.27 |
| Chiller-Boiler | 1568.54 | - | 918.47 | 462.17 | | | |
| | | | | | \$ 41,198.7 | \$ 12,325.9 | \$ 53,524.56 |
| Geothermal w/ | 1173.29 | - | 305.34 | 480.87 | | | |
| CHW/HW | | | | | \$ 20,637.7 | \$ 12,824.5 | \$ 33,462.21 |
| Geothermal+VAV(Rehe | _ | - | | | | | |
| at) | _ | | 1512.396 | 924.719 | \$ 40,334.8 | \$ 24,661.8 | \$ 64,996.54 |
| Sth Alt. System | | - | | | | | |
| | 539.384 | | - | 510.285 | \$ 5,744.0 | \$ 13,609.0 | \$ 19,353.05 |



Annual System Energy

| Penn State University – Architecture Engineering ■ Geothermal Cooling + HHW ■ Geothermal+HP ■ Baseli | Penn State University – Architecture Engineering | ■ Geothermal Cooling + HHW | ■ Geothermal+HP | ■ Baseline |
|--|--|----------------------------|-----------------|------------|
|--|--|----------------------------|-----------------|------------|

Limestone Silt Loam e Cooling **PLFm** [Btu/Hr] Rgd

[Btu/Hr]

Wc [W]

Lc [ft]

safety 15%

1.04

-44.61

0.201

0.120

0.225

0.09

52

-1352750 -1352750

24909.24 22844.02

4340

Total system

Geothermal+C Chiller-Boiler Geothermal+H

hillerBoiler

Summed total

% vs Baseline

Total system Total system energy

energy (MBtu) energy (MBtu) (MBtu

0.25

13202.87 8035.876

Differenc

1.04

-44.61

0.225

0.108

0.201

0.09

-1.8

4340

21660.21 19864.37 -1795.84